



Government of West Bengal
Office of the Divisional Fire Officer
West Bengal Fire & Emergency Services

First Floor of Midnapur Fire Station Sepoy Bazar, P.O.- Medinipur, P.S.- Kotwali, Pin:- 721101

Memo No.:FSR/1/0125186211400067

Date : 26-09-2024

From :
Divisional Fire Officer
Paschim Medinipur,
West Bengal Fire & Emergency Services

To :
TECHNO INDIA GROUP PUBLIC SCHOOL
PLOT NO- 1373,1374,1387,1378,1379,1384,1385,13 86,1358,1362,1375,1376,1377,1380, JL NO-286, KH NO-4268,
MOUZAPAIKPARI, PS - KOLAGHAT, PURBA MEDINIPUR - 721134

Sub : Fire Safety Certificate for an existing construction of G+III Storied building under group educational occupancy in the name & style of " TECHNO INDIA GROUP OF PUBLIC SCHOOL " at the premises of PLOT NO.- 1373, 1374, 1387, 1378, 1379, 1384, 1385, 1386, 1358, 1362, 1375, 1376, 1377, 1380, J.L. NO.- 286, KHATIAN NO.- 4268, MOUZA- PAIKPARI, P.S.- KOLAGHAT, DIST.- PURBA MEDINIPUR, PIN- 721134,

This is in reference to your AIN 211892406300001733 dated 05-Aug-2024 regarding Fire Safety Certificate for an existing construction of G+III Storied building under group educational occupancy in the name & style of " TECHNO INDIA GROUP OF PUBLIC SCHOOL " at the premises of PLOT NO.- 1373, 1374, 1387, 1378, 1379, 1384, 1385, 1386, 1358, 1362, 1375, 1376, 1377, 1380, J.L. NO.- 286, KHATIAN NO.- 4268, MOUZA- PAIKPARI, P.S.- KOLAGHAT, DIST.- PURBA MEDINIPUR, PIN- 721134, .

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Fire Safety Certificate** for occupancy of the aforesaid building.

Recommendation:

However, to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

1. All the Fire Safety Recommendation which was issued by this office vide memo no.- RFSR/0125186211400067 DT.- 14.10.2023 to be followed strictly at all time.
2. Driveway must be free from any type of obstruction for easy movement of fire appliances. No parking



will be allowed on the driveway.

3. The interior finish decoration of building shall be made with low flame spread material confirming to the I.S. Specification.

4. To eliminate risk of fire hazards, Good House Keeping both for inside and outside of the building shall be strictly maintained.

5. Electrical wiring of the whole building shall have to be carefully checked for any wire and tear in them, Particularly lines above false ceiling & ducts. Electrical safety Audit to be conducted positively by 31st March in every year.

6. A fire control room including a CCTV system will have to be maintained, which observe all floor of the building.

7. The notice of fire fighting and Evacuation from the shall be prepared and displayed at all venerable of the building.

8. The employees and security staff, shall be conversant with installed Fire Fighting equipment of the building and to operate in the event of fire and testing.

9. Mock fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.

10. Electrical installation room shall be protected with automatic CO2 or D.C.P. Fire extinguishers confirming I.S. Specification.

11. Unauthorized cooking arrangement in any floor of the hotel building except kitchen by using L.P.G., Kerosene etc. shall not be permitted and Fire License shall have to be obtained for storing and processing with L.P.G. and other highly combustible articles.

12. Arrangement shall have to be made for regular checking, testing and maintenance of all fire fighting installation in the building to keep them in perfectly good working condition at all the items.

13. Periodical flashing of water in the Hose reel hose pipe line shall made to maintain the efficiency working performance of above mention system.

14. The fire safety audit to be conducted a regular interval and to be recorded in the fire prevention maintenance register.

15. This certificate valid for 03 year from the date of issuance of this certificate.

A renewal certificate is to be obtained in every three year from the Director General, West Bengal Fire & Emergency Services for performance of all the life & fire safety arrangements and installations of the building.

Memo No.:FSR/1/0125186211400067

Valid Upto : 25-Sep-2027



Signature valid

Digitally Signed.
Name: Barun Kumar Chowdhury
Date: 26-Sep-2024 19:34:44
Reason: D-Sign
Location: E-Dist 2.0

Divisional Fire Officer

West Bengal Fire & Emergency Services